



ADDENDUM NUMBER 1

APPLE LIFT STATION & HWY-31 GENERATOR UPGRADES
FOR THE TOWN OF FALKVILLE
GMC PROJECT NO. CHUN240022

1. **General**

- 1.1 The following revisions are hereby added as Addendum No. 1 to the referenced Project Manual and Plans and shall be considered when preparing bids.

2. **Clarifications to Project Manual**

- 2.1 The Bypass connection at the Apple Lift Station will need to be made on the existing forcemain near the lift station. The nearest manhole which does not back feed to the Apple Lift Station is approximately 2,000 ft. away at the intersection of Pine Street and Cloud Street.
- 2.2 The concrete repairs to the wet well shall be made with waterproofing grouting in accordance with specification 03 60 00.
- 2.3 The existing aluminum wet well hatch shall be re-used if possible.

3. **Acknowledgement of Receipt**

- 3.1 Receipt of Addendum No. 1 shall be acknowledged in two ways:
 - 3.1.1 Note on Page 1A of the Proposal Form – Bidder acknowledges receipt of “Addendum No. 1” and date of “April 30th, 2025”.

AND

- 3.1.2 EMAIL the completed transmittal cover sheet to celina.beck@gmcnetwork.com to Acknowledge receipt of the Addendum.

4. **Conclusion**

- 4.1 This is the end of Addendum No. 1, dated Wednesday, April 30th, 2025.