



Goodwyn Mills Cawood
11 N. Water St., Suite 19290
Mobile, Alabama 36602
T 251.460.4006

TRANSMITTAL COVER SHEET

DATE: January 12, 2026
TO: ALL CONTRACTORS
FROM: DUSTINE TILL
PROJECT: ONO ISLAND BPS REPLACEMENT
ORANGE BEACH WATER AUTHORITY
GMC PROJECT NO. CMOB 230059
RE: ADDENDUM #1

PLEASE COMPLETE BELOW AND RETURN IMMEDIATELY.

Ashley Morris
Email: ashley.nobles@gmcnetwork.com

I, the undersigned, hereby acknowledge receipt of this Addendum.

Authorized Representative of Contractor

Date

Company Name

Telephone

Contractor's License Number (if applicable)



ADDENDUM NUMBER 1

ONO ISLAND BPS REPLACEMENT

FOR

ORANGE BEACH WATER AUTHORITY

GMC PROJECT NO. CMOB230059

1. Revisions to Project Manual

- 1.1 The following revisions are hereby added as Addendum No. 1 to the referenced Project Manual and Plans and shall be considered when preparing bids.

2. Questions

- 2.1 Will a delayed notice to proceed be allowed for the procurement of long lead time materials/equipment? Contract Duration is listed as 90 days to substantial completion and 120 days for final. **We will pause the time after the materials are ordered and then restart in October when construction can begin.**
- 2.2 Sheet E-002 shows the following electrical components called out as Sq. D. They no longer offer these items. Please confirm if Siemens is acceptable. **JRA: We will allow Siemens AND Square D. See below for additional clarification.**
- 200-amp, 480 volt fused disconnect with Integrated Surge -Sq. D. **JRA: Square D can provide an EXTERNAL SPD for the Main Fused Disconnect Switch. SPD enclosure type shall match that of the Main Fused Disconnect Switch. Main Fused Disconnect Switch shall have dual load-side lugs as required.**
 - Manual transfer switch with Visible Blade Type- Sq. D. **JRA: It is our understanding that Square D does offer this type of equipment. Alternatively, contractor could source from Ronk.**
 - NEMA 4X Stainless Steel Mini power zone- Sq. D. **JRA: Plans specify a NEMA 3R SS Mini Power Zone. Square D DOES offer this type of equipment.**

3. Acknowledgement of Receipt

- 3.1 Receipt of Addendum No. 1 shall be acknowledged in two ways:
- 3.1.1 Note on (EJCDC C-410) page 3 of Bid Form – Bidder acknowledges receipt of “Addendum No. 1” and date of “January 12, 2026”.

AND

- 3.1.2 EMAIL the signed transmittal sheet to ashley.nobles@gmcnetwork.com to confirm the addendum has been received and is legible.



4. Conclusion

4.1 This is the end of Addendum Number 1, dated Monday, January 12, 2026.